Head #8 MTS Collector Blanace Drawing Plan View SOLVENT TANK 。 「 MIST COLLECTOR Project: Honda Canada-Balance SN: 20071340 2000T Industrial Air Quality
95 Cypress Drive
Youngsville, NC 27596 P# 919-562-7181 F# 919-562-7182 PANEL 8"-8"-6" Branch 6" Butterffy damper Screen Cap AQ

Notes: A) Drop will have a Butterfly damper for airflow adjustment. B) Drop will have a bleed in port and butterfly damper to allow for balancing. C) ODF-2000 has 3.5HP 460volt 3Phase motor. Full load amps are 4.6amps. D) Drain line by Honda.

Drawing: Head #8

Date: 09/10/08|Drawn by:WWB

Sheet No: 8 of 8 | Rev.:0