

OSKAR AIR PRODUCTS

FIELD REPORT

95 Cypress Drive
Youngsville, North Carolina 27596
E-mail: bvenezia@oskarsales.com or mconnors@oskarsales.com

Phone: (919) 570-2862

Fax: (919) 570-2863

Page: 1 of 2

Date: 12/14/09

Project#: Missoula

OAP Crew: Bill, Rob, Rodney, Dan

Customer: Roscoe Steel
5404 Momont Rd.
Missoula, MT 59808
Attn: Joe Means

Installation: X
Service:
Warranty:
Repair:

Scope Of Project

- 1) 12/1/09
 - a. Traveled to Missoula
 - b. Unloaded two trucks in Missoula
- 2) 12/09/09
 - a. Ran inlet duct from collector into building
 - b. Worked with Missoula personnel to set first boom mounting plate, Boom and arm
- 3) 12/10/09
 - a. Ran 14" header to C1, C2 & C4
 - b. Installed arms
- 4) 12/11/09
 - a. Ran duct work to C7A, and one side of C6 & C5
 - i. One drop on C7A
 - ii. Two Drop on C6 & C5
 - b. Started 18" duct run
 - c. Hung all 5 arms on this run
- 5) 12/12/09
 - a. Ran duct work to Other side of C6 & C5
 - b. Installed all four arm on this line
 - c. Ran 18" header over door and down to duct height
- 6) 12/13/09
 - a. Ran duct to C9 & C8
 - b. Installed arms (Total of six)
 - c. Ran both 20 air return lines into building
 - d. Removed all excess material from shop area
- 7) 12/14/09
 - a. Finished sealing dust collector
 - b. Finished sealing return air duct
 - c. Packed all excess material into two trailers
 - d. Adjusted all boom arms
 - e. Conducted unit start-up
 - f. Operated all pulse valve – one may be leaking slightly by
 - g. Set air pressure to 90 psi – Regulator is blowing air of bleed hole
 - h. Cleaned our work area

OSKAR AIR PRODUCTS

FIELD REPORT

95 Cypress Drive
Youngsville, North Carolina 27596
E-mail: bvenezia@oskarsales.com or mconnors@oskarsales.com

Phone: (919) 570-2862
Fax: (919) 570-2863
Page: 2 of 2

Joe,
Please review and sign below. Make any comments that you feel are necessary.
Again I want to say that it was very enjoyable working with you and your people.
Your shop is a "CLASS" act.

Bill Boisvert, Project Manager
Industrial Air Quality (For Oskar Air Products)
919-971-3910
bboisvert@iaqsales.com

To Whom It May Concern:

The four individuals on the Oskar team very knowledgeable at their profession and with the Oskar system. They would give us good ideas and suggestion so we could ensure that our system would work the way we wanted it to and it was the way we wanted the duct work ran through the shop.

This team was a pleasure to work with and would welcome them back to help out if we needed it.

Thank you,
Joe Means
Plant Foreman



CUSTOMER SIGNATURE: _____

Joe Means

DATE: 12/17/09

TITLE OR DEPARTMENT: _____

Plant Foreman