





Notes:

A) ODF 4000TF Motor:
5HP at 480volts 7.8FLA

B) Drain Line: 1/2" PVC with
ball valve. Where do you
want it to run to?


C) Ductwork: Can it hang
from the ceiling? At what
height do you want the
bottom of the duct off of
the floor?



PROJ.# N/A		PROJECT NAME	
BLDG.# 1-191M		BUILDING NAME PB 2	
FLOOR 1ST		SCALE HTS	DATE
EXISTING	YES	CAD DWG.#	10/27/06
PROPOSED		M:\PLANT_3\191M\PLG\191M_L01.DWG	
PREPARED BY JEFF CODY			
PHONE # 623-3304		WICHITA, KANSAS	



PROJ.# ??-???-??		PROJECT NAME	
BLDG.# ?-????		BUILDING NAME ?	
FLOOR		SCALE ?"=1'-0"	DATE
EXISTING		CAD DWG.#	??/??/??
PROPOSED		??\??\???	
PREPARED BY ?			
PHONE # ???-????		WICHITA, KANSAS	
		N	



PROJECT #	N/A	PROJECT NAME	N/A
BLDG #	S-191M	BUILDING NAME	pg-2
FLOOR 1ST		SCALE	NFS
EXISTING	YES	CAD DWG #	DATE
PROPOSED		W:\PLANT\S\S191M\PLG\191M_LO1.DWG	10/12/06
PREPARED BY	JEFF CODY		
PHONE #	523-3304	WICHITA, KANSAS	N