


**INLET/OUTLET  
FLANGE CONNECTION**



**GENERAL NOTES**

1. ONE (1) UNIT REQUIRED, SHOWN AS RIGHT HAND ACCESS.
2. CONSTRUCTION: THE UNIT IS INTERMITTENTLY WELDED AND CAULKED WITH AN RTV SEALANT.
3. MATERIAL: THE UNIT SHALL BE MANUFACTURED FROM 12 GA. AND 14 GA. GALVANIZED STEEL MATERIAL.
4. WING NUTS AND STUDS SHALL BE USED TO RETAIN DOORS. A NEOPRENE GASKET SHALL SEAL THE DOOR EDGES TO THE ENCLOSURE.
5. UNIT COMES EQUIPPED WITH A REMOVABLE LOCKING TRAY MECHANISM FOR GASKET SEAL FILTERS.
6. ALL HEPA FILTERS SHALL SEAL ON THE DOWNSTREAM SIDE OF THE UNIT.
7. THE SYSTEM IS DESIGNED TO ACCOMMODATE THE FOLLOWING FILTERS:  
TWO (2) 24" X 24" X 2" NOM. PREFILTERS  
TWO (2) 24" X 24" X 1'-1/2" ACTUAL SIZE FINAL FILTERS

**APPROVAL PRINT**

APPROVED  
 APPROVED AS NOTED  
 REVISE AND RESUBMIT DATE: \_\_\_\_\_

**AIR CLEANING TECHNOLOGY, INC.**

PLYMOUTH, MN 55441  
 PHONE NO.: 800-422-1316  
 FAX NO.: 763-557-9731  
**A.C.T.**

REV. A	ATM	8/26/10	UPDATED BORDER	WMA	8/26/10	DATE:	8/26/10	TITLE	1H X 2W HEPA SIDE ACCESS	DWG SCALE	
DRAWN BY: ATM				DATE: 8/26/10				CONTROL NO. GH1-212P-10H20W-GALV		SHEET 1 OF 1	
APPROVED BY: WMA				DATE: 8/26/10				DRAWING NO.: 10-214		REV. A	

THE DEVICE DEPICTED AND DESCRIBED HEREON IS THE PROPERTY OF AIR CLEANING TECHNOLOGY, INC. ALL DESIGN, MANUFACTURING, REPRODUCTION, SALES, AND PATENT RIGHTS REGARDING THIS DEVICE OR DRAWING ARE RESERVED FOR AIR CLEANING TECHNOLOGY, INC.

UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE IN INCHES  
 \* TOLERANCES ARE:  
 FRACTION: ±1/8"  
 DECIMAL: ±.125"  
 ANGULAR: ±1°