

OSKAR ENVIRONMENTAL INC.

FIELD REPORT

Customer: Accellent
200 S. Yorkshire Street
Salem, VA 24153
Contact: Gary Marceau
Phone: 540-389-3002 x257
Email:

Date: 7/27/10
Project #: 00R 2000s
Sales Order #:
Serial #:
Model #:

OE Crew: Brian & Dan K.

SCOPE OF PROJECT: Installation Service - Warranty - Demo - Delivery - Engineering

Tuesday - Installed both plumb boxes on Absorbent Units. Cut legs down to 14" and installed under Absorbent Units. Ran duct to 3 machines and hung using Gripples.

Wednesday - Ran duct to other 2 machines. Installed flex duct from line to machine connections. Moved 3" line per Gary's Request. Ran both drain lines to pump box. Installed both Charcoal filters on top of Absorbent units. Cleaned up and brought duct home.

* Both Systems Complete *
* Gary will fax signed report in the morning.

CUSTOMER REMARKS:

Customer Signature: Gary Marceau
Title or Department:
95 CYPRESS DRIVE
YOUNGSVILLE, NORTH CAROLINA 27596
PHONE: (919) 570-2862 FAX: (919) 570-2863

Date: 7/29/10

SERVICE@OSKARSALES.COM
WWW.OSKARSALES.COM
PAGE of