Ductwork Layout for Dust Collector

Oskar Dust Collector
28,000 CFM
Model SV-6000
75 Hp motor
460 volts
FLA are 97.5
60 Cartridges
Filtering area 10,368FT2



Industrial Air Quality 102 AG DRIVE Youngsville, NC 27596 P# 919-562-7181 F# 919-562-7182	IAQ
Project: Altec	
Drawing: Ductwork layout	
Date: 4/18/08	Drawn by: RAV
Sheet No:	