



# EUROVAC

116 BUTTERMILL AVE.  
CONCORD, ONTARIO, CANADA L4K 3X7  
TEL: 1-800-265-3878 FAX: 905-738-4603  
WWW.EUROVAC.COM

## NOTES:

1. ALL LOCATIONS AND DISTANCES ARE APPROX.
2. VACUUM EQUIPMENT AREA TO BE PROPERLY VENTILATED.
3. ALL HANGING VACUUM DROPS REQUIRE 1/2" AIR DOWN AT CEILING LEVEL, JUST BELOW TRUSS, WITH SHUTOFF VALVE, TO BE 12" OFF OUR VACUUM DROP AND REDUCED DOWN AS NECESSARY BY OTHERS.
4. ALL WALL/SURFACE MOUNT DROPS REQUIRE 1/2" AIR DOWN TO 45" A.F.F. WITH SHUTOFF VALVE AND CUSTOMER SUPPLIED DISCONNECT WITHIN 6" OF VACUUM DROP BY OTHERS.
5. PULSE JET SEPARATORS REQUIRE 1/2" AIR DOWN, TO BE CONNECTED TO RESERVOIR TANK OF SEPARATOR BY OTHERS, MUST BE CLEAN, DRY, FILTERED AIR.
6. CUSTOMER TO VERIFY THE FOLLOWING:
  - a) ALL LOCATIONS
  - b) ALL DISTANCES
  - c) BUILDING ELEVATION AND ACCESS
  - d) LINE VOLTAGE

## VAC SYSTEM LEGEND: QUANTITY

○ SINGLE WORKSTATION	9
● DOUBLE WORKSTATION	1

## REVISIONS

REV. NO.	DATE	BY
REV. A	2/06/08	KG
REV. B	2/07/08	KG
REV. C		

CUSTOMER:	COASTAL PLAIN VENTURES, LLC SWAINSBORO, GA	
SHEET TITLE:	EUROVAC VACUUM SYSTEM EQUIPMENT/TUBE LAYOUT	
DRAWN BY:	KG	DATE: 2/06/08
CHECKED BY:	EE	SCALE: 1/16"=1'
APPROVED BY:		JOB NO.: 21896

THIS DOCUMENT CONTAINS PROPRIETARY AND CONFIDENTIAL DATA OF EUROVAC. NO DISCLOSURE REPRODUCTION OR USE OF ANY PART THEREOF, MAY BE MADE WITHOUT WRITTEN PERMISSION OF THE COMPANY.