



Global Precision SO21179 Duct Layout



Notes:

1. Clamp together duct to support off of ceiling
2. Branch/Fire Damper/Throttle Valve/Mist Accumulator/Connecting Flange on ALL Drops
3. Blow-off Box on Machine 4 ONLY
4. Avani Environmental standard installation crew is quoted out per day based on the drawings and approvals. Any changes, modifications, downtime, or inability to perform our work above and beyond the control of Avani Environmental will charge an additional \$1,000 per work day (5 or more hours) per crew above what was initially quoted.

Avani Environmental Intl.
95 Cypress Drive
Youngsville, NC 27596
P# 919-570-2862 F# 919-570-2863

Avani

Project: Global Precision SO21179

Drawing: Duct Layout

Date: 3/20/14

Drawn by: MDT

Sheet No: 1 of 1

Rev 0