


Equipment Layout for DDR-2000



*Will add Fire Trace
to this drawing*

16" Legs

Machine Top

8" Angle Ring Adapters (3" high) - 2

- Note:
1. DDR-2000 dims: 27.6" x 30.7" x 95.3" High
 2. Drain to be capped off
 3. Unit on 16" legs
 4. Exhaust Fan 3.5hp

Industrial Air Quality 95 CYPRESS DRIVE 27596 Youngsville, NC F# 919-562-7182	IAQ
Project: Honda / Canada	
Drawing: DDR-2000 Layout	
Date: 1/15/08	Drawn by: WWB
Sheet No: 1	Df 1

Firetrace International Order Form

1/7/2008

Bill to:
Company Industrial Air Quality
Address 102 Ag Drive
City/State/Zip Youngsville, NC 27596
Attn: Bob Venezia
Phone 919-562-7182

Ship to:
Company
Address
City/St/Zip
Attn:

Discount %:

Same

For Honda / Canada

Terms Net 30 Days

Application:

Item	Qty	Part #	Description
1	1	951004	10lb. CO2 Assembly
2	1	204025	25ft FT Tubing
3	1	600066	Manual Release
4	1	200159	HP 90 Slip-On
5	1	200179	Straight Line Adapter
6	10	700002	CO2 Agent
7	1	400001	Pressure Switch
8	1	400027	Pressure Gauge
9	1	200171	Tube Mounting Clips
10	1	200181	Magnet Mounts
11	1	200151	Plastic Grommets
12	2	500024	CO2 Nozzles
13	2	201802	2 ft. Discharge Hose

*Firetrace
 Parts used at
 Honda*

Parts for one ODR2000 System

- 14
- 15
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25