


# Johnson Controls AS Found Air Velocity Reading Collector Inlet @ Flow Switch

Location #	Inlet to Collector	V	CFM
Test Point	V/P	V	CFM
1	0.15	1551	1657
2	0.26	2042	2182
3	1.81	5388	5757
4	3.67	7672	8198
5	2.95	6879	7350
6	0.10	1266	1353
7	1.56	5002	5345
8	3.45	7439	7948
9	0.12	1387	1482
10	1.37	4688	5009
11	3.56	7557	8074
12		0	0
13		0	0
14		0	0
15		0	0
Average	1.73	5264	5624
Duct Area:	1.07		

Length	Width	Area SF
		0.00
	Diameter	
	14	1.07



Test Points

Avani Environmental Intl. 95 Cypress Drive Youngsville, NC 27596 PH 919-570-2862 F# 919-570-2863	<b>Avani</b>
Project: Johnson Controls	
Drawing: AS Found Readings	
Date: 2/15/11	Drawn by: WWB
Sheet No: 3 of 5	Rev: 0