

Johnson Controls AS Found Air Velocity/Flow Reading Fan Outlet @ Silencer

Location #		Fan Discharge		
Test Point	VP	V	CFM	
1		4000	5239	
2		3950	5173	
3		3800	4977	
4		3900	5108	
5		3890	5095	
6		0	0	
7			0	
8		0	0	
9		0	0	
10		0	0	
11		0	0	
12		0	0	
13		0	0	
14		0	0	
15		0	0	
Average	0.00	0	5118.29	
Duct Area:	1.31			

Length	Width	Area SF
		0.00
	Diameter	
	15.5	1.31

