


# Ductwork Layout for 3 Machines

Plan View



Notes:

- A) This typical for one installation.
- B) ODF 2000 will hang from ceiling. Bottom of unit about 9' off of floor.
- C) Drain line: PVC P-trap with ball valve and run back to machine.
- D) ODF 2000 motor is a 3.5HP. At 460 volts full load amps are 5.5amps.

Note:

Install the 6" butterfly dampers in the vertical position. Clamp to the angle flange adaptor.

Industrial Air Quality 102 AG DRIVE Youngsville, NC 27596 P# 919-562-7181 F# 919-562-7182	<b>IAQ</b>
Project: Sonic Tools	
Drawing: Duct layout for 3	
Date: 11/10/08	Drawn by: RAV
Sheet No:	