



ELECTRICAL REQUIREMENTS FOR 18925	
AVANI ENVIRONMENTAL INTERNATIONAL, INC.	
1720 Robert C. Jackson Drive Maryville, TN 37801 Phone: (919) 570-2862 Fax: (919) 570-2863	
SUPPLY VOLTAGE :	208VAC, 3 PHASE, 200AMP
TOTAL CONNECTED HP :	50 KW: 30
TOTAL CONNECTED KVA :	52
FULL LOAD AMPS :	144
MAIN FUSE OR BREAKER :	200 AMPS
SHORT CIRCUIT ENCLOSURE RATING :	25,000 AMPS
SHORT CIRCUIT EXTERNAL RATING :	25,000 AMPS
120VAC REQUIRED	N/A AMPS
24VDC REQUIRED	N/A AMPS

6.500"

8.500"

COMPLETE AUTOMATION RESOURCE

7216 BELDING ROAD, ROCKFORD, MI 49341

Drawn: AEH Date: 08/09/12 Scale: NONE File: C5350-E0005 Sheet: E0005

Title: PANEL LABELS

For: AVANI ENVIRONMENTAL P. O. 4942

REV	DATE	DESCRIPTION	DWN

REVISIONS

REV	DATE	DESCRIPTION	DWN

NOTICE
 THIS DRAWING IS QUOTE IN COMPLIANCE WITH THE REQUIREMENTS OF THE NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) AND IS NOT TO BE USED FOR DISSEMINATION AND BE MADE AVAILABLE TO THE PUBLIC WITHOUT THE WRITTEN CONSENT OF COMPLETE AUTOMATION RESOURCE. ALL RIGHTS ARE RESERVED SPECIFICALLY HEREBY.

COPYRIGHT 2010
 COMPLETE AUTOMATION RESOURCE

SHEET NUMBER
E0005